

9 Bronze Inspector's Test Gauge Cock

Description

- NETA Bronze Inspector's Test Gauge Cock
- Screwed BSP Parallel Female Threads
- With Bend 3/4" BSW Inspector's Gauge Connection

Test Pressure

Max. BOP : 250 PSIG

Max. Working Temperature : 220°C

Test Pressure : 500 PSIG Hyd.

Certification

IBR Test Certificate in FORM III-C duly signed by the Director of Boilers, Punjab is provided.

Application : Steam, Water

HSN : 84818020



Materials

PNo.	Part	Nos.	Material	Standard
1	Plug	1	Bronze	IBR 282[a][iv] Gr.B
2	Gasket	1	C.A.F.	IS:2712
3	Nut	1	Bronze	IBR 282[a][iv] Gr.B
4	Washer	1	C.A.F.	IS:2712
5	Body	1	Bronze	IBR 282[a][iv] Gr.B
6	Union Nut	1	Bronze	IBR 282[a][iv] Gr.B
7	Tail Pipe	1	Bronze	IBR 282[a][iv] Gr.B
8	Plug	1	Bronze	IBR 282[a][iv] Gr.B
9	Spring Washer	1	Spring Steel	-
10	Nut	1	Brass	IS:6912 Gr.FLB
11	Washer	1	Bronze	IBR 282[a][iv] Gr.B

Dimensions

Nominal Size (Inches)	Nominal Size (mm)	L ±3	H App.	W App.	T
3/8	10	136	65	92	3/8
1/2	15	140	65	92	1/2

